



The Corporation of Loyalist Township
P.O. Box 70, 263 Main Street Odessa, ON K0H 2H0

t: 613-386-7351 f: 613-386-3833 www.loyalist.ca

File: D03 – Windlectric

October 3, 2016

Algonquin Power Co.
354 Davis Road, Suite 100
Oakville, Ontario
L6J 2X1

Attn: Ariel Bautista, Project Manager

Dear Ariel:

Re: Review of Workplan & Geotechnical Investigation, 2nd Submission


Thank you for providing the above-noted report for our review. Our consultant, G.D. Jewell Engineering Inc., has prepared a response compiled from their observations as well as Loyalist Township staff comments on the report. We are pleased to attach these for your review and comment.

Please do not hesitate to contact the undersigned at 613-386-7351, ext. 117, should you have any questions.

Yours truly,

David MacPherson, C.E.T.
Public Works Manager
DM/ka

Encl.



www.jewelleng.ca

**BELLEVILLE
MAIN OFFICE**

1-71 Millennium Pkwy.
Belleville, ON
K8N 4Z5
Tel: 613-969-1111
Fax: 613-969-8988
Toll Free:
1-800-966-4338
info@jewelleng.ca

**MISSISSAUGA
BRANCH OFFICE**

2155 Leanne Blvd.
Suite 200A,
Mississauga, ON
L5K 2K8
Tel: 905-855-1592
Fax: 905-855-5428
Toll Free:
1-800-966-4338
mississauga@jewelleng.ca

**KINGSTON
BRANCH OFFICE**

Suite 208,
4 Cataraqui Street
Kingston, ON
K7K 1Z7
Tel: 613-389-7250
Fax: 613-389-2754
Toll Free:
1-800-966-4338
kingston@jewelleng.ca

**G.D. Jewell
ENGINEERING Inc.**

4 Cataraqui Street Suite 208
Kingston ON K7K 1Z7

September 27, 2016

Mr. David MacPherson C.E.T.
Manager of Public Works

Loyalist Township
263 Main Street, P.O. Box 70
Odessa, ON K0H 2H0

Dear Mr. MacPherson:

Project No: 150-3800

**Regarding: Review of Work Plan, Geotechnical Investigation, 2nd Submission
Amherst Island Wind Energy Project**

We have completed our review of the report entitled "Work Plan, Geotechnical Investigation, Municipal Roads" prepared by Stantec and dated September 14, 2016. Our comments are as follows:

The objectives of the Geotechnical Investigation have been revised and provide a refined purpose for the investigation. While we agree that the geotechnical study offers valuable information regarding existing road conditions, it should not be considered a replacement for the Pre-Construction Study that is a requirement of the Road Use Agreement (Section 18 and 19 of the Agreement).

Section 2.0 states that a Public Road Assessment has been completed. This assessment should be forwarded to the Township prior to Windlectric Inc. undertaking any work.

Section 3.2.1 indicates that neither an encroachment permit nor road occupancy permit is required for the investigation. Until all required information under the Road Use Agreement has been received, Windlectric Inc. shall secure all necessary approvals and permits.

Section 3.2.4 states that a road closure will be implemented for the work on Dump Road. A permit will be required for a road closure.

The schedule provided in Section 5.0 will have to be updated to reflect actual dates.

The consultant should have legal survey information to determine whether drilling activities are within the public right of way or on private lands. The consultant should obtain written permission for access to private lands where access is required.

Approval of the geotechnical work plan should not be construed as approval for the proposed works.

Closing

Guy Laporte, P. Eng. of G.D. Jewell Engineering Inc., assisted in preparation of this letter.

Sincerely,

G.D. Jewell Engineering Inc.


Dan Fencott, C.E.T.

Project Manager

DF/df



Professional Engineers
Ontario

Authorized by the Association of Professional Engineers
of Ontario to offer professional engineering services.

Consulting
Engineer