



The Corporation of Loyalist Township
P.O. Box 70, 263 Main Street Odessa, ON K0H 2H0

t: 613-386-7351 f: 613-386-3833 www.loyalist.ca

August 24, 2017

Algonquin Power Co.
354 Davis Road
Oakville, ON
L6J 2X1

Attn: Riley Griffin, Environmental Planner

Dear Mr. Griffin:

Re: Review of Fill Permit Application

Loyalist Township's consultant has completed their review of the Algonquin Power's Fill Permit Application Submission. The application relates to the Island Transmission Line on the Gavlas property. The following comments are provided:

- As noted in the application, the fill permit will pertain only to that portion of the works that is on private lands. Entrance permits will be covered under the approved Pre-Construction Survey.
- AP must indicate where surplus soils from turbine and access road construction will be disposed of; turbine drawings indicate a stockpile location – will this be used for surplus material from turbine construction? Will it also be used for surplus materials from road construction? Will it be big enough?
- AP must indicate where fill material for road construction will be sourced. Will it be surplus material from cut areas on same access road or will it require haulage on Township roads? If significant haulage is required then the access road construction cannot proceed in advance of road improvements.
- A stormwater management design brief for the transmission lines was prepared stating that no SWM is required. However, sediment and erosion controls during construction are necessary. Reinstatement of the work area with topsoil and seed will help to re-establish the vegetative cover.

Kindly review and return comment on these items at your earliest convenience. Please contact the undersigned at 613-386-7351, ext. 117, if you have any questions.

Yours truly,

David MacPherson, C.E.T.
Public Works Manager
DM/ka

CC: Dan Fencott, G.D. Jewell Engineering
Guy Laporte, G.D. Jewell Engineering
Robert Maddocks